

TEST CERTIFICATE

of the slide-blocking property in wet loaded barefoot areas of floor coverings

Tested material: **Resilient floor covering made of polyvinyl chloride**
(PVC according to DIN EN 649)
Signification: **ELEGANCE SD**
Dimensions: **roll goods** (l = 20 m; b = 2.0 m);
thickness 2.4 mm (incl. burls)
Colour: **yellow orange patterned**
(description: small grainy)
Surface: **unprofiled with burl structure**
(d = 7.0 mm; h = 0.5 mm; middle distance 29.0 mm)

Testing object: Delivery of the test material was effected in ready-to-test surface condition.

Producer / Supplier: **Gerflor Mipolam GmbH**
Mülheimer Straße 27/Tor 7
53840 Troisdorf

Applicant: Gerflor Mipolam GmbH
Mülheimer Straße 27/Tor 7
53840 Troisdorf

Date of order: 14.11.2007

Certificate number: 93130701.001e

Sampling: Sent by the customer to the research institute

Test method: **DIN 51097**, ed. 11/92
Requirements of the control-committee
"Side-blocking Floorings – List NB"

Test result: **Average inclination angle 18°**

Assessment: **Requirements** on the slide-blocking property for the range of application **B** are fulfilled.

SÄUREFLIESNER-VEREINIGUNG E. V.

Institute for wall and floor coverings
Managing Director



Dr.-Ing. E. H. Nolting



Großburgwedel, 20.12.2007
Schu/FI

This test-certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test-specimen. The report is given for 5 years (beginning data of delivery report). Publication and reproduction of this report is only allowed in unabridged form.

– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de

