

**FRENCH REGULATION ON VOC EMISSIONS  
COMPLIANCE CERTIFICATE**

**DECREE n° 2011-321 on March 23<sup>rd</sup> 2011 and DETAILS on April 19<sup>th</sup> 2011 regarding mandatory labelling of construction products installed indoors, floor and wall coverings, paints and lacquers**

Emissions classes based on emission testing  
From A+ (low level of emissions) to C (high level of emissions)



We confirm that the products  
**VIRTUO 30 RIGID ACOUSTIC**  
**VIRTUO 55 RIGID ACOUSTIC**  
comply with A+ class

Emissions measured after 28 days, in  $\mu\text{g}/\text{m}^3$ , according to ISO 16000 series

	A+ Class Limit values in $\mu\text{g}/\text{m}^3$	Compliance
Formaldehyde	<10	GERFLOR
Acetaldehyde	<200	
Toluene	<300	GERFLOR
Tetrachloroethylene	<250	
Xylene	<200	
1,2,4-Trimethylbenzene	<1000	
1,4-Dichlorobenzene	<60	
Éthylbenzene	<750	
2-Butoxyethanol	<1000	
Styrene	<250	
TVOC	<1000	

We confirm the following values :  
VOCT <  $10 \mu\text{g}/\text{m}^3$  formaldehyde <  $5 \mu\text{g}/\text{m}^3$

Saint Paul Trois Châteaux, March 7th 2023

Philippe MAGRO  
Technical Product Manager