

Slip Check to AS 4586-2013 Mipolam Planet

Report Number: M1166

Report Date: 26 August 2021

Total Number of Pages 2

Accredited for compliance with ISO/IEC 17025 – Testing

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration and inspection reports

Issued by

Safe Environments Pty Ltd
Unit 4, 40 Bessemer Street
Blacktown NSW 2148

Prepared for

Gerflor Australasia Pty Ltd
Cato Street
Hawthorn East VIC 3123

Approved by



Nasser Cura
Authorised Signatory

26 August 2021

Test Report No. M1166

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586-2013 Appendix D (Oil-Wet Inclining Platform Test)

The slip resistance classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface after classification. Standards Australia Handbook 198:2014 *Guide to the specification and testing of slip resistance of pedestrian surfaces* provides guidance for the selection of slip resistant pedestrian surfaces classified in accordance with AS 4586-2013. It is recommended that this test report be read in conjunction with AS 4586 and HB 198.

Requested by: Gerflor Australasia Pty Ltd
Client Address: Cato Street
Hawthorn East VIC 3123

Product Manufacturer: Gerflor
Product Description: Mipolam Planet
Surface Structure: Smooth
Fixed/Unfixed: Unfixed
Joint Width: N/A

Test conducted according to: AS 4586-2013 Appendix D (Incorporating Amendment No. 1)
Location: 4/40 Bessemer Street, Blacktown NSW 2148
Conducted by: Connor Murphy & Alexander Jovanovic
Test Shoe Type: Bergmann with LeipzigV73-SP sole form

Date: 26 August 2021
Cleaning: As Received
Air Temperature: 18°C

Displacement Space: Not Measured
Displacement Space Assessment Group: NA

| | |
|---|------------|
| Corrected Mean Overall Acceptance Angle: | 11° |
| Slip Resistance Assessment Group: | R10 |

This test report shall not be reproduced unless in full, without written approval of Safe Environments Pty Ltd