

ATTAR

Advanced Technology Testing and Research

ATTAR TEST REPORT NUMBER: 14/7552.2



The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards. Accredited for compliance with ISO/IEC 17025. Accreditation Number: 2735

15 January 2014

WET SLIP RESISTANCE

Job No: M14/7552

Total Pages: 1

Prepared for:	Gerflor Australasia Pty Ltd					
-	17 Cato Street					
	HAWTHORN EAST VIC 3123					
Attention:	Jutta Fronert					
Test Site:	ATTAR, Unit 1, 64 Bridge Road, Keysborough.					
Test Date:	15 January 2014					
Test Specimens, Size &	Mipolam Symbioz, homogenous sheet vinyl,					
Quantity:	200x200 mm, 5 off supplied.					
Sampling & Direction of Testing:	Sampling conducted by client. Test direction not applicable.					
Test Personnel:	Douglas Lehne					
Preparation:	Washed with water and pH neutral detergent, rinsed					
	with water, then dried.					
Fixed/Unfixed:	Unfixed.					
Air Temperature:	24°C					
Test Equipment:	Munro Stanley Skid Resistance Tester (Pendulum)					
	Serial Number 0320, Calibrated 16/10/2013.					
Test Standard:	AS 4586: 2013 Slip resistance classification of new					
	pedestrian surface materials – Appendix A.					
Slider Rubber:	Slider 96 Batch No. #50 prepared on P400 & 3µm					
	lapping film.					
Classification Criteria:	Refer to Classification Criteria, attached as Appendix 1.					
	Specimen Number					SRV
British Pendulum Number	1	2	3	4	5	SILV
	49	45	46	43	42	45
Classification:	P4					

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip-resistance be checked.

NOTE: Any specimens supplied will be disposed of in two (2) months time, unless otherwise instructed.

ATTAR

Douglas Lehne Floor Slip Tester Approved Signatory